

# EU-TYPE EXAMINATION CERTIFICATE



## Equipment or Protective System intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU

EU-Type Examination Certificate Number: **UL 21 ATEX 2397X Rev. 1**

Product: **LED Luminaires, Models L1319C Series – Models THTH1319C, THTH1319E, THTH1319D and THTH1319F Series**

Manufacturer: **Top Hi-Tech Co., Ltd.**

Address: **9F, No. 1, Zhongshan Rd., Tucheng District, New Taipei City 236, Taiwan (R.O.C)**

This product and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.

UL International Demko A/S, notified body number 0539 in accordance with Article 17 of the Council Directive 2014/34/EU of 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential report no. **US/UL/ExTR21.0038/01.**

Compliance with the Essential Health and Safety Requirements has been assured by compliance with:


**EN IEC 60079-0:2018**

**EN 60079-31:2014**

If the sign "X" is placed after the certificate number, it indicates that the product is subject to special conditions for safe use specified in the schedule to this certificate.

This EU-Type Examination Certificate relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by the certificate.

The marking of the product shall include the following:

 **II 2 D Ex tb IIIC T115°C...T110°C...T95°C Db**

**Certification Manager**  
Jan-Erik Storgaard

This is to certify that the sample(s) of the Product described herein ("Certified Product") has been investigated and found in compliance with the Standard(s) indicated on this Certificate, in accordance with the ATEX Product Certification Program Requirements. This certificate and test results obtained apply only to the product sample(s) submitted by the Manufacturer. UL did not select the sample(s) or determine whether the sample(s) provided were representative of other manufactured product. UL has not established Follow-Up Service or other surveillance of the product. The Manufacturer is solely and fully responsible for conformity of all product to all applicable Standards, specifications, requirements or Directives. The test results may not be used, in whole or in part, in any other document without UL's prior written approval.

**Date of issue:** 2021-04-20

**Re-issued:** 2022-06-13

**Notified Body**

UL International Demko A/S, Borupvang 5A, 2750 Ballerup, Denmark  
Tel. +45 44 85 65 65, [info.dk@ul.com](mailto:info.dk@ul.com), [www.ul.com](http://www.ul.com)

# Schedule

## EU-TYPE EXAMINATION CERTIFICATE No.

UL 21 ATEX 2397X Rev. 1

[13]

[14]

[15]

**Description of Product**

The Model L1319C Series of LED luminaires is suitable for use in hazardous location classified as Zone 21. This luminaire consists of "tb" LED array chamber.

Nomenclature for Luminaires:

The complete 2 feet luminaire catalogue number example is as follows:

Cat. No.	THT	H	1319	C	N	H	C	C	P0
	1	2	3	4	5	6	7	8	9

1 – Brand name

THT = Top Hi-Tech Co., Ltd.

2 – Category of product

H = HazLoc LED luminaire

3 – Model name

1319 = Model L1319C Series

4 – Designates series type and length of LED luminaire

C = 2ft length with clear glass

E = 2ft length with matted glass

5 – Designates type of Top Cover

N = Without Top Cover

C = With Top Cover

6 – Designates type of LED module

H = SMD type

B = COB type

7 – Designates CCT of LED

C = Cool white

W = Warm white

8 – Designates voltage of luminaire

4 = 100 Vac (For 20W/30W/40W/50W/60W/70W/80W/90W/100W/120W/150W only)

1 = 110 Vac (For 20W/30W/40W/50W/60W/70W/80W/90W/100W/120W/150W only)

6 = 120 Vac (For 20W/30W/40W/50W/60W/70W/80W/90W/100W/120W/150W only)

5 = 200 Vac (For 20W/30W/40W/50W/60W/70W/80W/90W/100W/120W/150W only)

2 = 220 Vac (For 20W/30W/40W/50W/60W/70W/80W/90W/100W/120W/150W only)

D = 230 Vac (For 20W/30W/40W/50W/60W/70W/80W/90W/100W/120W/150W only)

9 = 277 Vac (For 20W/30W/40W/50W/60W/70W/80W/90W/100W/120W/150W only)

F = 347 Vac (For 20W/40W/80W only)

C = 480 Vac (For 20W/40W/80W only)

H = 100~277 Vac (For 30W/40W/50W/60W/70W/80W/90W/100W/110W/120W/130W/140W/150W/160W only)

L = 125 Vdc (For 30W/35W/40W/45W/50W/55W/60W only)

9 – Designates wattage of luminaire

B0 = 20W (For 100V/110V/120V/200V/220V/230V/277V/347V/480V only)

C0 = 30W (For 100V/110V/120V/200V/220V/230V/277V/100~277V/125Vdc only)

C5 = 35W (For 125Vdc only)

D0 = 40W (For 100V/110V/120V/200V/220V/230V/277V/347V/480V/100~277V/125Vdc only)

D5 = 45W (For 125Vdc only)

E0 = 50W (For 100V/110V/120V/200V/220V/230V/277V/100~277V/125Vdc only)

E5 = 55W (For 125Vdc only)

F0 = 60W (For 100V/110V/120V/200V/220V/230V/277V/100~277V/125Vdc only)

G0 = 70W (For 100V/110V/120V/200V/220V/230V/277V/100~277V only)

H0 = 80W (For 100V/110V/120V/200V/220V/230V/277V/347V/480V/100~277V only)

I0 = 90W (For 100V/110V/120V/200V/220V/230V/277V/100~277V only)

J0 = 100W (For 100V/110V/120V/200V/220V/230V/277V/100~277V only)

K0 = 110W (For 100~277V only)

L0 = 120W (For 100V/110V/120V/200V/220V/230V/277V/100~277V only)

M0 = 130W (For 100~277V only)

N0 = 140W (For 100~277V only)

P0 = 150W (For 100V/110V/120V/200V/220V/230V/277V/100~277V only)

Q0 = 160W (For 100~277V only)

Models covered are as follows:

Models	Ambient Temperature range	'tb' Temperature Rating
THTH1319vwHxyz	-20°C to +40°C	T95°C
	-20°C to +60°C	T115°C
THTH1319vwBxfn	-20°C to +40°C	T110°C
	-20°C to +45°C	T115°C

v can be C or E; w can be N or C; x can be C or W; y can be 4, 1, 6, 5, 2, D, 9, F, C, H or L; z can be B0, C0, C5, D0, D5, E0, E5, F0, G0, H0, I0, J0, K0, L0, M0, N0, P0 or Q0; f can be 1, 6, 2, D or 9; n can be D0, F0, H0, J0 or L0

# Schedule

## EU-TYPE EXAMINATION CERTIFICATE No.

### UL 21 ATEX 2397X Rev. 1

The complete 4 feet luminaire catalogue number example is as follows:

Cat.	THT	H	1319	D	C	H	C	C	30
No.	1	2	3	4	5	6	7	8	9

1 – Brand name

THT = Top Hi-Tech Co., Ltd.

2 – Category of product

H = HazLoc LED luminaire

3 – Model name

1319 = Model L1319C Series

4 – Designates series type and length of LED luminaire

D = 4ft length with clear glass

F = 4ft length with matted glass

5 – Designates type of Top Cover

C = With Top Cover

6 – Designates type of LED module

H = SMD type

B = COB type

7 – Designates CCT of LED

C = Cool white

W = Warm white

8 – Designates voltage of luminaire

4 = 100 Vac (For 40W/60W/80W/100W/120W/140W/160W/180W/210W/240W/300W only)

1 = 110 Vac (For 40W/60W/80W/100W/120W/140W/160W/180W/200W/210W/240W/300W only)

6 = 120 Vac (For 40W/60W/80W/100W/120W/140W/160W/180W/200W/210W/240W/300W only)

5 = 200 Vac (For 40W/60W/80W/100W/120W/140W/160W/180W/210W/240W/300W only)

2 = 220 Vac (For 40W/60W/80W/100W/120W/140W/160W/180W/200W/210W/240W/300W only)

D = 230 Vac (For 40W/60W/80W/100W/120W/140W/160W/180W/200W/210W/240W/300W only)

9 = 277 Vac (For 40W/60W/80W/100W/120W/140W/160W/180W/200W/210W/240W/300W only)

F = 347 Vac (For 40W/80W/160W only)

C = 480 Vac (For 40W/80W/160W only)

H = 100~277 Vac (For 120W/150W/160W/170W/180W/190W/200W/210W/220W/230W/240W/250W/260W/270W/280W/290W/300W only)

9 – Designates wattage of luminaire

D0 = 40W (For 100V/110V/120V/200V/220V/230V/277V/347V/480V only)

F0 = 60W (For 100V/110V/120V/200V/220V/230V/277V only)

H0 = 80W (For 100V/110V/120V/200V/220V/230V/277V/347V/480V only)

J0 = 100W (For 100V/110V/120V/200V/220V/230V/277V only)

L0 = 120W (For 100V/110V/120V/200V/220V/230V/277V/100~277V only)

N0 = 140W (For 100V/110V/120V/200V/220V/230V/277V only)

P0 = 150W (For 100~277V only)

Q0 = 160W (For 100V/110V/120V/200V/220V/230V/277V/347V/480V/100~277V only)

R0 = 170W (For 100~277V only)

S0 = 180W (For 100V/110V/120V/200V/220V/230V/277V/100~277V only)

T0 = 190W (For 100~277V only)

U0 = 200W (For 110V/120V/220V/230V/277V/100~277V only)

V0 = 210W (For 100V/110V/120V/200V/220V/230V/277V/100~277V only)

W0 = 220W (For 100~277V only)

X0 = 230W (For 100~277V only)

Y0 = 240W (For 100V/110V/120V/200V/220V/230V/277V/100~277V only)

25 = 250W (For 100~277V only)

26 = 260W (For 100~277V only)

27 = 270W (For 100~277V only)

28 = 280W (For 100~277V only)

29 = 290W (For 100~277V only)

30 = 300W (For 100V/110V/120V/200V/220V/230V/277V/100~277V only)

Models covered are as follows:

Models	Ambient Temperature range	'tb' Temperature Rating
THTH1319uCHxyzz	-20°C to +40°C	T95°C
	-20°C to +60°C	T115°C
THTH1319uCBxfp	-20°C to +40°C	T110°C
	-20°C to +45°C	T115°C

u can be D or F; x can be C or W; yy can be 4, 1, 6, 5, 2, D, 9, F, C or H; zz can be D0, F0, H0, J0, L0, N0, Q0, R0, S0, T0, U0, V0, W0, X0, Y0, 25, 26, 27, 28, 29 or 30; f can be 1, 6, 2, D or 9; p can be H0, L0, Q0, U0 or Y0

The optical radiation output of the product with respect to explosion protection, according to Annex II clause 1.3.1 of the Directive 2014/34/EU is covered in this certificate based on Exception 2) to the scope of EN 60079-28:2015.

[13]

[14]

## Schedule EU-TYPE EXAMINATION CERTIFICATE No. UL 21 ATEX 2397X Rev. 1

Electrical data:

Models	Length	Voltage (Vac)	Frequency (Hz)	Wattage (W)
THTH1319vwHxaB0	2ft	100/110/120/200/220/230/277/347/480	50/60	20
THTH1319vwHxbB0		100/110/120/200/220/230/277	50/60	20
THTH1319vwHxdC0		100/110/120/200/220/230/277/100~277/125Vdc	50/60	30
THTH1319vwHxeC5		125Vdc	50/60	35
THTH1319vwHxaD0		100/110/120/200/220/230/277/347/480	50/60	40
THTH1319vwBxfD0		110/120/220/230/277	50/60	40
THTH1319vwHxdD0		100/110/120/200/220/230/277/100~277/125Vdc	50/60	40
THTH1319vwHxeD5		125Vdc	50/60	45
THTH1319vwHxdE0		100/110/120/200/220/230/277/100~277/125Vdc	50/60	50
THTH1319vwHxeE5		125Vdc	50/60	55
THTH1319vwHxbF0		100/110/120/200/220/230/277	50/60	60
THTH1319vwBxfF0		110/120/220/230/277	50/60	60
THTH1319vwHxdF0		100/110/120/200/220/230/277/100~277/125Vdc	50/60	60
THTH1319vwHxgG0		100/110/120/200/220/230/277/100~277	50/60	70
THTH1319vwHxcH0		120/277/347/480	50/60	80
THTH1319vwBxfH0		110/120/220/230/277	50/60	80
THTH1319vwHxgH0		100/110/120/200/220/230/277/100~277	50/60	80
THTH1319vwHxgI0		100/110/120/200/220/230/277/100~277	50/60	90
THTH1319vwBxfJ0		110/120/220/230/277	50/60	100
THTH1319vwHxgJ0		100/110/120/200/220/230/277/100~277	50/60	100
THTH1319vwHxhK0		100~277	50/60	110
THTH1319vwHxbL0		100/110/120/200/220/230/277	50/60	120
THTH1319vwBxfL0		110/120/220/230/277	50/60	120
THTH1319vwHxhL0		100~277	50/60	120
THTH1319vwHxhM0		100~277	50/60	130
THTH1319vwHxhN0		100~277	50/60	140
THTH1319vwHxbP0		100/110/120/200/220/230/277	50/60	150
THTH1319vwHxpP0		100~277	50/60	150
THTH1319vwHxhQ0		100~277	50/60	160
THTH1319uCHxaD0		100/110/120/200/220/230/277/347/480	50/60	40
THTH1319uCHxbD0		100/110/120/200/220/230/277	50/60	40
THTH1319uCHxbF0		100/110/120/200/220/230/277	50/60	60
THTH1319uCHxaH0		100/110/120/200/220/230/277/347/480	50/60	80
THTH1319uCBxfH0		110/120/220/230/277	50/60	80
THTH1319uCHxbH0		100/110/120/200/220/230/277	50/60	80
THTH1319uCHxbJ0		100/110/120/200/220/230/277	50/60	100
THTH1319uCHxbL0		100/110/120/200/220/230/277	50/60	120
THTH1319uCBxfL0		110/120/220/230/277	50/60	120
THTH1319uCHxgL0		100/110/120/200/220/230/277/100~277	50/60	120
THTH1319uCHxbN0		100/110/120/200/220/230/277	50/60	140
THTH1319uCHxpP0		100~277	50/60	150
THTH1319uCHxcQ0		120/277/347/480	50/60	160
THTH1319uCBxfQ0		110/120/220/230/277	50/60	160
THTH1319uCHxgQ0		100/110/120/200/220/230/277/100~277	50/60	160
THTH1319uCHxhR0		100~277	50/60	170
THTH1319uCHxgS0		100/110/120/200/220/230/277/100~277	50/60	180
THTH1319uCHxhT0		100~277	50/60	190
THTH1319uCBxfU0		110/120/220/230/277	50/60	200
THTH1319uCHxhU0	100~277	50/60	200	
THTH1319uCHxgV0	100/110/120/200/220/230/277/100~277	50/60	210	
THTH1319uCHxhW0	100~277	50/60	220	
THTH1319uCHxhX0	100~277	50/60	230	
THTH1319uCHxbY0	100/110/120/200/220/230/277	50/60	240	
THTH1319uCBxfY0	110/120/220/230/277	50/60	240	
THTH1319uCHxhY0	100~277	50/60	240	
THTH1319uCHxh25	100~277	50/60	250	
THTH1319uCHxh26	100~277	50/60	260	
THTH1319uCHxh27	100~277	50/60	270	
THTH1319uCHxh28	100~277	50/60	280	
THTH1319uCHxh29	100~277	50/60	290	
THTH1319uCHxb30	100/110/120/200/220/230/277	50/60	300	
THTH1319uCHxh30	100~277	50/60	300	
v can be C or E; u can be D or F; w can be N or C; x can be C or W; a can be 4, 1, 6, 5, 2, D, 9, F or C; b can be 4, 1, 6, 5, 2, D or 9; c can be 6, 9, F or C; d can be 4, 1, 6, 5, 2, D, 9, F, C, H or L; e can be L; f can be 1, 6, 2, D or 9; g can be 4, 1, 6, 5, 2, D, 9 or H; h can be H				

Routine tests:

Routine test is not required.

[13]

[14]

**Schedule**  
**EU-TYPE EXAMINATION CERTIFICATE No.**  
**UL 21 ATEX 2397X Rev. 1**

[16]

Descriptive Documents

The scheduled drawings are listed in the report no. provided under item no. [ 8 ] on page 1 of this EU-Type Examination Certificate.

[17]

Specific conditions of use:

- The luminaire shall not be opened.
- Potential electrostatic charging hazard – see instructions.
- The gasket not to be replaced in the field.

[18]

Essential Health and Safety Requirements

The Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9.

Additional information

The Models L1319C Series has in addition passed the tests for Ingress Protection to IP66 in accordance with EN60529:1991+A1:2000+A2:2013.

The trademark **THT-EX** or **THT-EX** will be used as the company identifier on the marking label.

The manufacturer shall inform the notified body concerning all modifications to the technical documentation as described in Annex III to Directive 2014/34/EU of the European Parliament and the Council of 26 February 2014.