EU-TYPE EXAMINATION CERTIFICATE



Equipment or Protective System intended for use in Potentially Explosive Atmospheres
Directive 2014/34/EU

- [3] EU-Type Examination Certificate Number: **DEMKO 18 ATEX 2131X Rev. 0**
- [4] Product: LED Luminaires, Models L1512 Series
- [5] Manufacturer: **Top Hi-Tech Co. Ltd.**


[2]

- [6] Address: 9F, No.1, Zhongshan Rd., Tucheng Dist., New Taipei City 236, Taiwan (R.O.C)
- [7] This product and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.
- [8] UL International Demko A/S, notified body number 0539 in accordance with Article 17 of the Council Directive 2014/34/EU of 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

 The examination and test results are recorded in confidential report no. 4788382630.1.1
- [9] Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 60079-0:2012+A11:2013 EN 60079-31:2014

- [10] If the sign "X" is placed after the certificate number, it indicates that the product is subject to special conditions for safe use specified in the schedule to this certificate.
- [11] This EU-Type Examination Certificate relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by the certificate.
- [12] The marking of the product shall include the following:



Certification Manager Jan-Erik Storgaard This is to certify that the sample(s) of the Product described herein ("Certified Product") has been investigated and found in compliance with the Standard(s) indicated on this Certificate, in accordance with the ATEX Product Certification Program Requirements. This certificate and test results obtained apply only to the product sample(s) submitted by the Manufacturer. UL did not select the sample(s) or determine whether the sample(s) provided were representative of other manufactured product. UL has not established Follow-Up Service or other surveillance of the product. The Manufacturer is solely and fully responsible for conformity of all product to all applicable Standards, specifications, requirements or Directives. The test results may not be used, in whole or in part, in any other document without UL's prior written approval.

Date of issue: 2018-09-19

Notified Body

UL International Demko A/S, Borupvang 5A, 2750 Ballerup, Denmark Tel. +45 44 85 65 65, info.dk@ul.com, www.ul.com

[14]

Schedule EU-TYPE EXAMINATION CERTIFICATE No. DEMKO 18 ATEX 2131X Rev. 0

[15] <u>Description of Product:</u>

The Model L1512 Series of LED luminaires is suitable for use in hazardous location classified as Zone 21. This luminaire consists of one "tb" chamber.

Nomenclature for Luminaires:

The complete luminaire catalogue number example is as follows:

Cat.	THT	Н	1512	Α	N	Α	С	9	U0
No.	1	2	3	4	5	6	7	8	9

1 - Brand name

THT = Top Hi-Tech Co., Ltd.

2 - Category of product

H = HazLoc LED lighting

3 - Model name

1512 = Model L1512 series

4 - Designates material of PC Cover

A = Transparent PC

5 – Designates type of Top Cover

N = No Top Cover exist

6 - Designates type of LED module

A = DOB type

K = SMD type

7 - Designates CCT of LED

C = Cool white

W = Warm white

8 - Designates voltage

1 = 110 Vac

2 = 220 Vac

9 = 277 Vac

9 - Designates wattage of LED lighting

N0 = 140 W

Q0 = 160 W

S0 = 180 W

U0 = 200 W

Models covered are as follows:

Model	Ambient Temperature range	Gas Temperature Code	Dust Temperature Rating
THTH1512ANA*1N0	-20°C to +40°C	T6	T85°C
THTH1512ANA*1Q0	-20°C to +40°C	T6	T85°C
THTH1512ANA*1S0	-20°C to +40°C	T6	T85°C
THTH1512ANA*1U0	-20°C to +40°C	T6	T85°C
THTH1512ANK*1N0	-20°C to +40°C	T6	T85°C
THTH1512ANK*1Q0	-20°C to +40°C	T6	T85°C
THTH1512ANK*1S0	-20°C to +40°C	T6	T85°C
THTH1512ANK*1U0	-20°C to +40°C	T6	T85°C
THTH1512ANA*2N0	-20°C to +40°C	T6	T85°C
THTH1512ANA*2Q0	-20°C to +40°C	T6	T85°C
THTH1512ANA*2S0	-20°C to +40°C	T6	T85°C
THTH1512ANA*2U0	-20°C to +40°C	T6	T85°C
THTH1512ANK*2N0	-20°C to +40°C	T6	T85°C
THTH1512ANK*2Q0	-20°C to +40°C	T6	T85°C
THTH1512ANK*2S0	-20°C to +40°C	T6	T85°C
THTH1512ANK*2U0	-20°C to +40°C	T6	T85°C
THTH1512ANA*9N0	-20°C to +40°C	T6	T85°C
THTH1512ANA*9Q0	-20°C to +40°C	T6	T85°C
THTH1512ANA*9S0	-20°C to +40°C	T6	T85°C
THTH1512ANA*9U0	-20°C to +40°C	T6	T85°C
THTH1512ANK*9N0	-20°C to +40°C	T6	T85°C
THTH1512ANK*9Q0	-20°C to +40°C	Т6	T85°C
THTH1512ANK*9S0	-20°C to +40°C	Т6	T85°C
THTH1512ANK*9U0	-20°C to +40°C	T6	T85°C

The optical radiation output of the product with respect to explosion protection, according to Annex II clause 1.3.1 of the Directive 2014/34/EU is not covered in this certificate.

[13]

[14]

Schedule EU-TYPE EXAMINATION CERTIFICATE No. DEMKO 18 ATEX 2131X Rev. 0

Temperature range:

The ambient temperature range is -20°C ≤Ta ≤ +40°C.

Electrical data

THTH1512ANA*1N0 - 110 Vac, 50/60 Hz, 140 W THTH1512ANA*1Q0 - 110 Vac, 50/60 Hz, 160 W THTH1512ANA*1S0 - 110 Vac, 50/60 Hz, 180 W THTH1512ANA*1U0 - 110 Vac, 50/60 Hz, 200 W THTH1512ANK*1N0 – 110 Vac, 50/60 Hz, 140 W THTH1512ANK*1Q0 – 110 Vac, 50/60 Hz, 160 W THTH1512ANK*1S0 - 110 Vac, 50/60 Hz, 180 W THTH1512ANK*1U0 - 110 Vac, 50/60 Hz, 200 W THTH1512ANA*2N0 - 220 Vac, 50/60 Hz, 140 W THTH1512ANA*2Q0 - 220 Vac, 50/60 Hz, 160 W THTH1512ANA*2S0 - 220 Vac, 50/60 Hz, 180 W THTH1512ANA*2U0 - 220 Vac, 50/60 Hz, 200 W THTH1512ANK*2N0 - 220 Vac, 50/60 Hz, 140 W THTH1512ANK*2Q0 - 220 Vac, 50/60 Hz, 160 W THTH1512ANK*2S0 - 220 Vac, 50/60 Hz, 180 W THTH1512ANK*2U0 - 220 Vac, 50/60 Hz, 200 W THTH1512ANA*9N0 - 277 Vac, 50/60 Hz, 140 W THTH1512ANA*9Q0 - 277 Vac, 50/60 Hz, 160 W THTH1512ANA*9S0 - 277 Vac, 50/60 Hz, 180 W THTH1512ANA*9U0 - 277 Vac, 50/60 Hz, 200 W THTH1512ANK*9N0 - 277 Vac, 50/60 Hz, 140 W THTH1512ANK*9Q0 - 277 Vac, 50/60 Hz, 160 W THTH1512ANK*9S0 - 277 Vac, 50/60 Hz, 180 W

Routine tests:

Routine is not required.

[16] <u>Descriptive Documents</u>

The scheduled drawings are listed in the report no. provided under item no. [8] on page 1 of this Type Examination Certificate.

[17] Special Conditions of Use:

• The luminaire shall not be opened.

THTH1512ANK*9U0 - 277 Vac, 50/60 Hz, 200 W

- Potential electrostatic charging hazard see instructions.
- The luminaire does not have a test port fitted.

[18] <u>Essential Health and Safety Requirements</u>

The Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9.

Additional information

The Models L1512 series has in addition passed the tests for Ingress Protection to IP67 in accordance with EN60529:1991+A1:2000+A2:2013.





THT-EX

will be used as the company identifier on the marking label.