

CERTIFICATE OF COMPLIANCE

Certificate Number E523344
Report Reference E523344-20220307
Date 2022-March-08

Issued to: Top Hi-Tech Co Ltd
9F 1 Zhongshan Rd
Tucheng District
New Taipei 236 TW

**This is to certify that
representative samples of**

AUXILIARY DEVICES FOR USE IN HAZARDOUS
LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: See Addendum Page

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E523344
Report Reference E523344-20220307
Date 2022-March-08

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Auxiliary Devices For Use In Hazardous Locations, Class I, Division 2, Groups A, B, C and D, Class II, Division 2, Groups F and G, Class III.

USL, CNL Indicator Tower Light, Model L1920 series Class I, Division 2, Groups A, B, C and D, Class II, Division 2, Groups F and G, Class III

Standard(s) for Safety

Standard No. UL 121201, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations

Standard No. CSA C22.2 NO. 213, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations

UL 508 - STANDARD FOR INDUSTRIAL CONTROL EQUIPMENT


CSA C22.2 NO. 14-18 - STANDARD FOR INDUSTRIAL CONTROL EQUIPMENT

UL 50E, Enclosures for Electrical Equipment, Environmental Considerations

Standard for Enclosure for Electrical Equipment, Environmental Considerations, CSA C22.2 No. 94.2-15

UL 50, Enclosures for Electrical Equipment, non-Environmental Considerations

Standard for Enclosure for Electrical Equipment, non-Environmental Considerations, CSA C22.2 No. 94.1-15



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

